



# CARROLL COUNTY FIRE RESCUE

## FIRE MARSHAL'S OFFICE

501 Old Newnan Road • Carrollton, GA 30117

[www.carrollcountyfirerescue.com](http://www.carrollcountyfirerescue.com)

Phone: 770.830.5880

**David Harmon**

Fire Marshal

**Nicole Brigham**

Captain

## **Temporary Consumer Fireworks Stand Fire Inspection Checklist**

Temporary Consumer Fireworks Stands shall be erected/constructed, stocked with product, and ready for sale before a fire inspection from the Fire Marshal's Office can occur. After a successful fire inspection has been completed then a Temporary Fireworks Stand Permit will be issued. The permit is no longer valid after the expiration date or if the location of the stand changes during the permitted time frame. The following items will be inspected by the Fire Marshal's Office:

1. Adequate exits
2. "No Smoking" signs posted, all sides
3. "18-year-old to purchase" sign prominently posted
4. Lighting and electrical per fire code
5. Fire Extinguisher(s) (minimum (1) 4A rating)
6. Generator & gasoline approved storage
7. Verify operator's state fireworks license
8. Verify Date of Birth of fireworks stand staff
9. On site storage of stock
10. Trash storage/removal
11. Verify "Permissible" fireworks only
12. Quantity of fireworks
13. Stand adequately constructed and anchored
14. Clearance to public way (25') and inhabited buildings (50')
15. 25' Clearance around stand of ignition sources and combustible materials

To request a Fireworks Stand Permit, visit the Carroll County Fire Rescue Website at [www.carrollcountyfirerescue.com](http://www.carrollcountyfirerescue.com). Once on the Fire Rescue homepage you'll find a link on the right-hand side to Request A Permit. The Carroll County Fire Marshal's Office requires a 5-day notice in advance to schedule the permit inspection.